

BRIDGEWATER TOWNSHIP SANITARY INSPECTION REPORT

IDENTIFICATION					
OWNER INFORMATION <i>(Complete this section only if different from establishment information)</i>			ESTABLISHMENT INFORMATION		
NAME OF OWNER(S), CORPORATION OR REGISTERED AGENT <i>PIC - Kristine</i>			ESTABLISHMENT TRADING NAME <i>Lifetime Fitness</i>		
NUMBER AND STREET <i>Phone - 908-800-5122</i>		COUNTY	NUMBER AND STREET <i>145 Commons Way</i>		COUNTY <i>Somerset</i>
MUNICIPALITY <i>Kevin Rule - 908-800-5122</i>	STATE	MUNICIPALITY <i>Bridgewater</i>	ZIP CODE <i>08807</i>	TELEPHONE NO.	
ZIP CODE	COMUN. CODE	ESTABLISHMENT STATE LICENSE NO. (if appl.)	COMUN. CODE		
INSPECTION					
TYPE OF ESTABLISHMENT <input type="checkbox"/> RETAIL <input checked="" type="checkbox"/> POOL <input type="checkbox"/> CAMP <input type="checkbox"/> OTHER		ESTABLISHMENT CODE <input type="checkbox"/> DESTROYED <input type="checkbox"/> EMBARGOED		<input checked="" type="checkbox"/> INITIAL INSPECTION <input type="checkbox"/> REINSPECTION <i>(other than initial inspection)</i>	
				TIME - (2400 HOURS)	
		DATE	BEGIN	END	
		<i>6/14/2022</i>	<i>10:45am</i>	<i>12:30</i>	
EVALUATION					
<input checked="" type="checkbox"/> SATISFACTORY <input type="checkbox"/> CONDITIONALLY SATISFACTORY <input type="checkbox"/> UNSATISFACTORY					
OFFICIAL(S)					
LOCAL BOARD OF HEALTH			INSPECTING OFFICIAL		
NAME, ADDRESS AND TELEPHONE NUMBER Bridgewater Township 100 Commons Way Bridgewater, N.J. 08807 908-725-5750			INSPECTOR'S NAME AND TITLE <i>Patricia Tinko-Parker / Shahira Morell</i>		
			INSPECTOR'S SIGNATURE <i>Patricia Tinko-Parker / Shahira Morell</i>		
HEALTH OFFICER <i>Health Officer Kevin Sumner</i>			INSPECTOR'S PERM. REG. NO. <i>B1934 / B144238</i>		

CONTINUATION SHEET

(for Inspections, Surveys, Audits, etc.)

Name (Individual, Facility, Establishment, etc.)
Lifetime Pools

Date
6/14/2022

BRIDGEWATER TOWNSHIP

Item No.	Remarks
	PTC - Kristine
	CPO - Kevin Rule exp 4/30/27
	Lifeguard certs. up to date
	AED - pads ok Emergency Phones - ok
	First Aid kits - ok
	Lifesaving Equipment ok
	Lig Books maintained + in pump room - ok
	OUT DOOR POOL - * need outside NJ Bathing Rules posted.
	* SPA outside - Need clock posted + visible from inside spa.
	Note - Batteries were charging for handicap lift
	Note - Jacuzzis + cold plunge in men's locker room drained once a week usually
	Note - To send CB20 + Emergency Action Plan to have in file
	<u>Indoor Pools:</u>
	Women's Spa + men's spa - spoke to PTC about jagged tile upon entry points
	Note: Men's + Women's locker rooms have sauna + steam rooms. Just men's cold plunge.
	Note: At time of inspection, glass bottles were in men's locker room. No glass allowed sign is posted. To enforceible "Potential Hazard" posted. SATISFACTORY

Signature of Individual Completing Form

Signature of Owner of Facility, Establishment, etc. if required

[Handwritten signatures]

[Handwritten signature]