

BRIDGEWATER TOWNSHIP SANITARY INSPECTION REPORT

IDENTIFICATION

OWNER INFORMATION <i>(Complete this section only if different from establishment information)</i>		ESTABLISHMENT INFORMATION		
NAME OF OWNER(S), CORPORATION OR REGISTERED AGENT		ESTABLISHMENT TRADING NAME <i>Spring Run Pool</i>		
NUMBER AND STREET	COUNTY	NUMBER AND STREET	COUNTY	
		<i>1722 West Circle Drive</i>	<i>Somerset</i>	
MUNICIPALITY	STATE	MUNICIPALITY	ZIP CODE	TELEPHONE NO.
		<i>Bridgewater</i>	<i>08807</i>	
ZIP CODE	COMUN. CODE	ESTABLISHMENT STATE LICENSE NO. (if appl.)	COMUN. CODE	

INSPECTION

TYPE OF ESTABLISHMENT	ESTABLISHMENT CODE	<input checked="" type="checkbox"/> INITIAL INSPECTION <input type="checkbox"/> REINSPECTION <i>(other than initial inspection)</i>		
<input type="checkbox"/> RETAIL <input checked="" type="checkbox"/> POOL <input type="checkbox"/> CAMP <input type="checkbox"/> OTHER	GOODS <input type="checkbox"/> DESTROYED <input type="checkbox"/> EMBARGOED	TIME - (2400 HOURS)		
		DATE	BEGIN	END
		<i>6/1/2021</i>		

EVALUATION

 SATISFACTORY

 ~~CONDITIONALLY SATISFACTORY~~
 UNSATISFACTORY

OFFICIAL(S)

LOCAL BOARD OF HEALTH	INSPECTING OFFICIAL
NAME, ADDRESS AND TELEPHONE NUMBER Bridgewater Township 100 Commons Way Bridgewater, N.J. 08807 908-725-5750	INSPECTOR'S NAME AND TITLE <i>Patricia Timko-Parker</i> <i>R.E.H.S.</i>
	INSPECTOR'S SIGNATURE <i>Patricia Timko-Parker</i>
HEALTH OFFICER <i>Kevin Sumner</i>	INSPECTOR'S PERM. REG. NO. <i>B1934</i>

CONTINUATION SHEET

(for Inspections, Surveys, Audits, etc.)

Name (Individual, Facility, Establishment, etc.)
Spring Kun Pool

Date
 6/1/2021

BRIDGEWATER TOWNSHIP

Item No.	Remarks
8-26-5.2f1	Note: Need to submit diagram for facility within Aquatics Facility plan. CPO states submitted diagram last year & will resend.
	PH 7.2 chlorine 5
8-26-7.3a	Note: CB20 Drain cover form to be submitted. Garden State was called and is supposed to come test water. To have passing test before opening.
	Covid Contact person - Gregg Cherbonneau 732-648-3412
	Lifeguard Certs - 2 lifeguards or 1 expires tomorrow 6/2/2021.
	Note: Specially Exempt facility. Not required to have a lifeguard.
8-26-4.12	Depth markings - Wearing off of depth markings on the concrete. CPO states will have them repainted.
8-26-5.3(7)	Note: Emergency phone will be turned on prior to opening. Need a throw line that can reach other side of pool

Signature of Individual Completing Form
Patricia M. Parker

Signature of Owner of Facility, Establishment, etc. if required
Gregg