

BRIDGEWATER TOWNSHIP SANITARY INSPECTION REPORT

IDENTIFICATION					
OWNER INFORMATION <i>(Complete this section only if different from establishment information)</i>			ESTABLISHMENT INFORMATION		
NAME OF OWNER(S), CORPORATION OR REGISTERED AGENT			ESTABLISHMENT TRADING NAME <i>Stratton Meadows Pool</i>		
NUMBER AND STREET		COUNTY	NUMBER AND STREET		COUNTY
			<i>1 Meghan Pool</i>		<i>Somerset</i>
MUNICIPALITY		STATE	MUNICIPALITY	ZIP CODE	TELEPHONE NO.
			<i>Bridgewater</i>	<i>08807</i>	
ZIP CODE	COMUN. CODE		ESTABLISHMENT STATE LICENSE NO. (if appl.)	COMUN. CODE	
INSPECTION					
TYPE OF ESTABLISHMENT		ESTABLISHMENT CODE		<input checked="" type="checkbox"/> INITIAL INSPECTION	
<input type="checkbox"/> RETAIL				<input type="checkbox"/> REINSPECTION <i>(other than initial inspection)</i>	
<input checked="" type="checkbox"/> POOL		GOODS		TIME - (2400 HOURS)	
<input type="checkbox"/> CAMP		<input type="checkbox"/> DESTROYED		DATE	BEGIN
<input type="checkbox"/> OTHER		<input checked="" type="checkbox"/> EMBARGOED		<i>5/18/2022</i>	
EVALUATION					
<input type="checkbox"/> SATISFACTORY		<input checked="" type="checkbox"/> CONDITIONALLY SATISFACTORY		<input type="checkbox"/> UNSATISFACTORY	
OFFICIAL(S)					
LOCAL BOARD OF HEALTH			INSPECTING OFFICIAL		
NAME, ADDRESS AND TELEPHONE NUMBER <i>Bridgewater Township 100 Commons Way Bridgewater, N.J. 08807 908-725-5750</i>			INSPECTOR'S NAME AND TITLE <i>Patricia Timka Parker</i>		
			INSPECTOR'S SIGNATURE <i>Patricia Timka Parker</i>		
HEALTH OFFICER <i>Kevin Sumner</i>			INSPECTOR'S PERM. REG. NO. <i>B1934</i>		

CONTINUATION SHEET

(for Inspections, Surveys, Audits, etc.)

Name (Individual, Facility, Establishment, etc.)

Stratton Meadows Pool

Date

5/18/2022

BRIDGEWATER TOWNSHIP

Item No.	Remarks
	- Preopening Inspection for Stratton Meadows Pool
	CPO - Patrick Miller, cert. on file
	Bonding & Grounding ok
	Twp Electrical Inspection Pending.
	Chlorine - 1.5
	First Aid kit ok
	PH - 7.4
	Defibrillator ok
	Log Book onsite
	Safety Equip ok
	Aquatic Facilities Plan ok
	Note: Garden State Labs
	* Preoperational Checklist NOT submitted
	* Depth markings on concrete have faded. To restencil.
	* CB20 Form needed for file
	* Pool over 2000 ft ² - only one stand for Lifeguard onsite.
	* Emergency Phone in Clubhouse can call 911 but not
	Note: WADING POOL currently not operational. Fully
	CANNOT open unless inspected by Health Functioning
	* OKAY to open pending Twp. Electrical Inspection
	PASSES.
	Conditionally Satisfactory

Signature of Individual Completing Form

[Signature]

Signature of Owner of Facility, Establishment, etc. if required

RAFAEL ADENO SR
[Signature]