

BRIDGEWATER TOWNSHIP SANITARY INSPECTION REPORT

IDENTIFICATION

OWNER INFORMATION <i>(Complete this section only if different from establishment information)</i>		ESTABLISHMENT INFORMATION		
NAME OF OWNER(S), CORPORATION OR REGISTERED AGENT		ESTABLISHMENT TRADING NAME <i>Bridgewater Ymca Pool</i>		
NUMBER AND STREET	COUNTY	NUMBER AND STREET	COUNTY	
		<i>601 Garrielson Rd</i>	<i>Somerset</i>	
MUNICIPALITY	STATE	MUNICIPALITY	ZIP CODE	TELEPHONE NO.
		<i>Bridgewater</i>	<i>08807</i>	
ZIP CODE	COMUN. CODE	ESTABLISHMENT STATE LICENSE NO. (if appl.)	COMUN. CODE	


INSPECTION

TYPE OF ESTABLISHMENT	ESTABLISHMENT CODE	<input checked="" type="checkbox"/> INITIAL INSPECTION <input type="checkbox"/> REINSPECTION <i>(other than initial inspection)</i>		
<input type="checkbox"/> RETAIL <input checked="" type="checkbox"/> POOL <input type="checkbox"/> CAMP <input type="checkbox"/> OTHER	GOODS <input type="checkbox"/> DESTROYED <input type="checkbox"/> EMBARGOED	TIME - (2400 HOURS)		
		DATE	BEGIN	END
		<i>6/16/2022</i>		

EVALUATION

SATISFACTORY
 CONDITIONALLY SATISFACTORY
 UNSATISFACTORY

OFFICIAL(S)

LOCAL BOARD OF HEALTH	INSPECTING OFFICIAL
NAME, ADDRESS AND TELEPHONE NUMBER Bridgewater Township 100 Commons Way Bridgewater, N.J. 08807 908-725-5750	INSPECTOR'S NAME AND TITLE <i>Patricia Timko-Parker</i> <i>R.E.H.S.</i>
	INSPECTOR'S SIGNATURE 
HEALTH OFFICER <i>Kevin Summer</i>	INSPECTOR'S PERM. REG. NO. <i>B1934</i>

CONTINUATION SHEET

(for Inspections, Surveys, Audits, etc.)

Name (Individual, Facility, Establishment, etc.)

YMCA POOLS

Date

6/16/2022

BRIDGEWATER TOWNSHIP

Item No.	Preoperational Checklist - <i>OK</i>	Remarks
	CPO cert. <i>OK</i> on file	
	Log Book <i>OK</i>	
	Electrical Inspection Trwp <i>OK</i> May 2022	
	Lifeguard Certs in book - checked <i>OK</i>	
	Safety Equipment <i>OK</i> <u>except</u>	
	a Throw line	
	Restrooms <i>OK</i>	
	AED <i>OK</i> PAD <i>OK</i>	
	Note: Inside depth markings not present. To check if "grandfathered" in and get back to PIC / Bonding & Grounding <i>OK</i>	
	Kiddy Pool - <i>OK</i>	
	3 Lifeguard stands for 6800 ft ² - 2 needed for over 2000 ft ²	
	Garden State Labs sends water reports to Health Dept. Hours - 5am - 10 pm	
	CB20 on file. ASHRAE Facility Plan on file.	
	POOL + KIDDY POOL RATED "SATISFACTORY"	

Signature of Individual Completing Form

Patricia [Signature]

Signature of Owner of Facility, Establishment, etc. if required

[Signature]